



UNIVERSITY OF CENTRAL FLORIDA

Department of Procurement Services
12424 Research Parkway, Suite 355
Orlando, FL 32826

ADDENDUM

IMPORTANT DOCUMENT – INVITATION TO NEGOTIATE

ITN NUMBER: 2023-17OCSA

ITN TITLE: Chemical Treatment Services Campus Water Loops

OPENING DATE & TIME: September 12, 2024; 3:00 PM

ADDENDUM NUMBER: II ADDENDUM DATE: September 5, 2024

Purpose of this addendum is to:

- **Extend the due date to September 12, 2024 at 3:00 PM EST.**
- **Revise section 7.0, C, to read:**
 - C. CHILLED WATER LOOP SYSTEM – assume the following values:**
 - 1. Make up system volume (gallons): 3,378,000**
 - 2. Average make up per year (gallons): 3,500,000**
- **Revise section 7.1 Price Summary to also include:**
 - Fountain/Reflection Pond: \$ _____**
 - Steam Boiler Locations: \$ _____**
 - Hot/Chilled Water Closed Loops: \$ _____**
- **To correct the UCF Answer on Addendum 1, question 17: The total amount of chlorine dioxide required is 1,126 lbs., not 2,200 lbs.**

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND RETURN IT WITH YOUR OFFER. FAILURE TO SIGN AND RETURN WITH YOUR OFFER COULD RESULT IN REJECTION OF YOUR OFFER.

PROPOSERS SIGNATURE

PRINT OR TYPE PROPOSER'S NAME

COMPANY NAME

EMAIL ADDRESS